

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 17-51-01125
Name of Facility: Beulah Academy of Science
Address: 8633 Beulah Road
City, Zip: Pensacola 32526

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Charter School
Owner: Beulah Academy of Science
Person In Charge: Kevin Bailey Phone: (850) 944-2822
PIC Email: KFBailey@BAScience.com

Inspection Information

Purpose: Routine
Inspection Date: 3/31/2023

Begin Time: 03:15 AM
End Time: 03:40 AM

Additional Information

FEMALES 148
MALES 159

CENSUS 307

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: **IN** = the act or item was observed to meet standards; **OUT** = the act or item was observed not to meet standards; **NO** = the act or item was not observed to be occurring at the time of inspection; **NA** = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

See violation comments #5 and 13.

Mr. Bailey is facility guide during inspection: 850-232-9684

KFBailey@BAscience.com

Email Address(es): KFBailey@BAscience.com

Violations Comments

Violation #5. Maintenance & Repair

Overhead vent hanging out of place in room 1. Secure vent into place.

Observed multiple ceiling tiles throughout the facility with water damage/stains and some ceiling tiles missing in boy restroom. Repair/Replace tiles as needed.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #13. Handwashing Facilities

Hot water registered 118F at handwashing sink in student restroom. PIC had plumber inspect the hot water heater and turn hot water temp down to 110F at the heater, however hot water at point of distribution still exceeds 110F. Registered at 118F at the time of inspection. PIC indicates that he will replace the hot water thermostat.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: Christie Gillenwater (027985)
Inspector Contact Number: Work: (850) 595-6700 ex. 2006
Print Client Name: Kevin Bailey
Date: 3/31/2023

Inspector Signature:

Handwritten signature of Christie Gillenwater.

Client Signature:

Handwritten signature of Kevin Bailey with an 'X' mark.