

# QUESTIONS AND ANSWERS

## ITB #171403 – HVAC AIR FILTERS

The following questions have been submitted concerning ITB #171403 – HVAC Air Filters. The questions below are provided verbatim from what was received. All questions received have been answered below.

**No further Addendums to the RFP will be issued and the opening date remains the same.**

- 1) Can you please tell me if these filters are standard capacity MERV 8 pleats, and are these specified as wire back pleated filters?

**Yes, the filters are standard capacity MERV 8 pleats. No, they are not specified as wire back pleated filters.**